

Support Trailer Operational Checks

Safety Notes: Report any item you may think unusual or out of place to the Comm Center so it can be addressed or corrected.

1. Check Tower.
 - a. If winds have increased to 40 MPH or higher lower the tower and attach safety ropes and stakes.
 - b. Check safety cones and flagging.
2. Shut down generator every 12 hours for safety checks.
 - a. Notify any agency connected to spider box of temporary loss of power.
 - b. Secure AC heaters, Linear, and microwave before securing power in the Comm Center.
 - c. Have Comm Center shift to AC Inverter.
 - d. Secure generator AC breakers before shut down.
 - e. Check oil level and fuel filters.
3. Change oil every 100 hours
 - a. Use Dell 400 oil.
 - b. Oil filter is Fram PH5046 or Napa 1334.
 - c. When new fuel is added, add anti jell and diesel fuel additive. (Note: try to refuel during the summer months to get thinner fuel)
4. Once inspection is completed.
 - a. Startup generator
 - b. Check with Comm Center to see if they are ready for power.
 - c. Turn on generator power breakers.
 - d. Check with agencies on spider box, to make sure they are ok.
 - e. Log into activity log.
5. Have Comm Center turn on required AC breakers to restore service.